

FADP-2 — Daily Report

20 Aug 2026 21:08 to 13 Sep 2026 21:08 — 5-minute intervals — STE Chemicals / FactoryTalk DataMosaix

	Column									Withdrawal		Boiler					Utility		
Timestamp	30-TIC-109 °C	30-TI-115 °C	30-TIC-124 °C	30-FIC-118 kg/hr	30-TI-128 °C	30-TI-137 °C	30-PT-127 mbar	30-PT-135 mbar	30-FT-140 kg/hr	30-FI-141 kg/hr	30-LIC-146 %	30-PT-160 Bar	30-TI-163 °C	30-TI-162 °C	TI-158 °C	30-FT_4_4 sm3/hr	30-SFM-15 Tons/hr	30-FI-141_PCT %	30-TDIFF °C
06-Sep 06:59	31.905	71.862	199.616	1282.691	222.5	261.67	6.204	11.5	-0.056	1176.953	15.365	62.257	277.3	273.928	257.745	23.808	0.629	92.046	2.797
06-Sep 07:04	32.77	75.171	198.798	1270.607	219.437	259.0	6.515	11.552	-0.073	1102.81	23.447	62.329	277.221	274.334	259.316	25.705	0.725	86.504	3.139
06-Sep 07:09	30.279	70.752	197.0	1264.731	221.013	262.873	6.522	13.25	-0.235	1128.758	21.233	62.339	277.045	274.625	257.955	24.264	0.719	87.876	2.874
06-Sep 07:14	30.817	79.21	198.664	1279.344	221.339	261.108	6.243	11.5	-0.141	1152.421	18.223	62.235	277.272	273.952	258.506	24.64	0.719	89.443	3.147
06-Sep 07:19	30.868	79.014	199.036	1308.652	220.022	261.339	6.489	12.755	-0.321	1138.103	16.912	62.218	277.105	273.865	258.368	22.982	0.727	89.736	3.358

Summary

	Column									Withdrawal		Boiler					Utility		
Timestamp	30-TIC-109 °C	30-TI-115 °C	30-TIC-124 °C	30-FIC-118 kg/hr	30-TI-128 °C	30-TI-137 °C	30-PT-127 mbar	30-PT-135 mbar	30-FT-140 kg/hr	30-FI-141 kg/hr	30-LIC-146 %	30-PT-160 Bar	30-TI-163 °C	30-TI-162 °C	TI-158 °C	30-FT_4_4 sm3/hr	30-SFM-15 Tons/hr	30-FI-141_PCT %	30-TDIFF °C
Average	31.99	74.85	200.01	1289.61	220.72	263.31	6.39	12.26	-0.2	1128.54	20.07	62.3	277.1	274.01	258.93	24.03	0.7	87.92	3.09
Max	34.5	93.88	202.5	1315.0	222.5	266.5	7.63	14.49	0.1	1197.0	30.24	62.4	277.3	274.7	260.3	25.9	0.75	94.5	3.7
Min	30.0	65.0	197.0	1248.24	218.05	259.0	5.9	11.5	-0.5	1038.25	14.9	62.2	276.8	273.4	256.2	21.01	0.56	79.35	2.5