

Timestamp	Treated Sweet Water			Thermo Compressor		Vaporisation Chambers			
	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C
04-Sep 07:19	3.04	31.701	33.627	0.606	75.281	0.962	95.582	72.277	65.538
04-Sep 07:24	2.155	29.9	33.638	1.038	81.632	0.9	91.136	77.931	47.172
04-Sep 07:29	3.039	29.9	33.999	0.898	80.137	0.9	103.24	71.383	58.644
04-Sep 07:34	2.395	32.808	33.551	0.357	81.016	1.182	99.071	70.839	60.198
04-Sep 07:39	2.988	34.487	33.629	0.564	78.21	1.213	91.065	68.922	60.847
04-Sep 07:44	2.646	34.72	34.189	0.565	80.556	1.118	96.109	69.965	61.363
04-Sep 07:49	1.751	31.462	33.829	0.356	77.268	0.9	96.827	74.465	67.376
04-Sep 07:54	1.989	32.643	33.899	0.582	77.498	1.031	94.733	71.347	56.155
04-Sep 07:59	3.597	30.736	33.631	0.918	78.621	1.092	92.749	72.394	55.134
04-Sep 08:04	2.272	29.9	33.484	0.244	79.0	1.443	88.571	68.387	61.322
04-Sep 08:09	3.892	29.9	33.958	0.292	75.845	0.9	99.624	72.422	65.858
04-Sep 08:14	2.705	31.385	33.753	0.307	80.987	0.9	94.236	70.208	58.481
04-Sep 08:19	3.26	31.284	33.742	0.851	74.728	0.949	99.157	68.471	57.474
04-Sep 08:24	3.359	31.844	33.709	-0.1	80.072	1.399	93.156	70.801	57.808
04-Sep 08:29	3.123	29.9	33.907	0.771	81.07	1.125	93.548	73.214	61.113
04-Sep 08:34	2.528	29.9	33.769	0.589	78.667	1.384	90.365	71.909	62.783
04-Sep 08:39	2.409	32.541	33.792	0.404	78.196	0.9	94.918	67.307	65.201
04-Sep 08:44	2.953	30.199	33.889	0.126	79.237	1.215	97.623	71.456	51.05
04-Sep 08:49	2.953	32.743	33.705	1.1	78.46	1.482	96.999	71.958	57.088
04-Sep 08:54	3.147	33.08	33.888	0.631	76.699	1.025	90.489	74.103	59.478
04-Sep 08:59	2.828	29.9	33.938	0.909	78.233	1.085	98.589	78.601	60.607
04-Sep 09:04	3.627	31.937	33.826	0.817	80.06	1.629	94.693	76.439	67.825
04-Sep 09:09	2.451	32.466	33.816	0.836	76.348	1.159	94.683	73.523	54.971
04-Sep 09:14	3.073	29.968	33.756	-0.1	79.168	1.311	96.146	71.571	59.256
04-Sep 09:19	2.871	32.348	33.512	0.079	78.306	1.302	99.531	74.097	61.731
04-Sep 09:24	3.047	32.156	34.2	0.898	80.118	1.059	92.205	75.032	59.643
04-Sep 09:29	2.747	31.908	33.805	1.057	77.768	0.945	95.035	70.197	56.099
04-Sep 09:34	2.58	32.817	33.409	0.41	82.882	1.381	97.954	70.399	64.093
04-Sep 09:39	2.342	32.286	34.2	0.548	81.181	1.414	94.721	71.035	55.093
04-Sep 09:44	4.138	31.52	34.066	0.922	78.717	1.028	96.864	74.026	62.879
04-Sep 09:49	3.272	33.715	33.942	0.921	81.232	1.077	96.346	74.104	62.617
04-Sep 09:54	3.625	32.775	33.873	0.515	80.307	1.258	94.19	74.249	60.164
04-Sep 09:59	3.018	34.598	33.835	1.079	79.186	1.239	90.311	75.091	63.996
04-Sep 10:04	2.876	31.407	33.845	0.61	78.075	1.47	96.011	75.366	58.437
04-Sep 10:09	2.446	31.552	33.997	0.503	78.943	1.132	94.038	76.807	59.992
04-Sep 10:14	3.141	31.863	34.028	0.595	75.16	1.182	91.158	76.29	58.833
04-Sep 10:19	1.924	30.914	34.2	0.597	77.472	1.089	96.811	74.739	61.824
04-Sep 10:24	3.011	33.508	33.733	0.397	79.381	0.9	90.874	73.1	63.502
04-Sep 10:29	3.406	34.141	33.949	0.711	78.865	1.13	95.657	72.984	61.262
04-Sep 10:34	3.82	34.015	33.755	0.633	78.688	1.225	96.461	74.604	60.846
04-Sep 10:39	1.968	32.568	33.666	0.598	79.541	1.433	94.844	75.244	62.908
04-Sep 10:44	3.336	31.73	33.837	0.734	81.543	1.065	91.612	70.122	64.872
04-Sep 10:49	3.248	30.918	33.958	0.917	76.908	0.945	100.312	67.25	63.04
04-Sep 10:54	3.547	30.738	33.837	0.571	81.742	1.063	96.09	71.118	60.582

Timestamp	Treated Sweet Water			Thermo Compressor	Vaporisation Chambers				
	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C
04-Sep 10:59	2.9	32.974	33.996	1.1	77.519	1.104	107.779	69.04	62.13
04-Sep 11:04	3.173	32.224	33.809	0.973	77.395	1.47	94.917	72.246	61.18
04-Sep 11:09	3.696	32.195	33.512	0.337	78.231	0.9	94.746	74.669	55.551
04-Sep 11:14	2.015	32.149	33.705	0.989	83.175	1.14	97.254	75.828	61.622
04-Sep 11:19	3.109	32.026	33.709	0.498	78.167	1.515	100.333	75.469	62.461
04-Sep 11:24	3.315	34.575	34.063	0.965	81.522	1.222	92.869	73.534	58.868
04-Sep 11:29	2.161	32.126	33.642	0.701	77.727	1.09	98.294	72.034	62.093
04-Sep 11:34	3.234	32.753	33.826	0.658	83.896	1.249	93.77	74.292	66.871
04-Sep 11:39	3.67	33.313	33.743	0.685	80.93	1.551	98.701	67.352	62.208
04-Sep 11:44	3.58	31.488	33.83	0.573	76.407	1.157	99.412	75.015	57.148
04-Sep 11:49	4.442	32.058	33.974	0.61	79.416	1.106	88.695	78.577	65.583
04-Sep 11:54	3.586	32.312	33.439	0.239	80.648	0.9	97.235	76.624	62.411
04-Sep 11:59	2.498	31.181	33.832	0.792	83.029	1.116	91.739	76.423	67.225
04-Sep 12:04	2.87	30.909	33.605	0.283	81.453	1.253	94.967	75.668	68.634
04-Sep 12:09	1.929	33.627	33.87	0.488	76.429	1.176	86.915	74.401	62.636
04-Sep 12:14	2.846	33.711	34.051	0.545	81.472	0.9	94.375	80.242	62.524
04-Sep 12:19	3.727	29.9	33.713	0.733	78.883	1.173	89.957	79.717	64.236
04-Sep 12:24	3.098	34.234	33.951	0.645	77.032	1.209	85.0	74.097	60.968
04-Sep 12:29	2.567	32.183	33.824	0.713	79.377	1.299	96.827	77.048	62.733
04-Sep 12:34	3.413	32.195	34.02	0.905	80.872	1.214	96.457	75.086	56.717
04-Sep 12:39	4.089	31.732	33.685	0.5	79.729	1.258	95.961	76.05	61.409
04-Sep 12:44	2.397	31.44	33.92	0.495	82.469	1.048	100.115	69.095	57.248
04-Sep 12:49	3.279	33.009	34.147	1.1	77.185	0.944	95.362	76.158	64.526
04-Sep 12:54	3.326	30.462	34.2	0.781	78.63	1.148	89.946	74.578	58.585
04-Sep 12:59	3.271	31.426	34.167	0.391	80.185	1.25	90.624	72.256	59.617
04-Sep 13:04	2.43	34.387	33.976	0.608	78.944	1.544	96.029	72.069	66.89
04-Sep 13:09	3.163	32.298	33.968	0.293	79.244	1.245	93.122	72.847	59.706
04-Sep 13:14	3.291	29.9	34.002	0.732	79.016	1.297	95.519	73.246	72.1
04-Sep 13:19	3.956	31.448	34.053	0.969	80.444	1.445	100.8	74.108	57.891
04-Sep 13:24	3.595	31.062	34.091	0.242	77.937	0.9	92.939	76.597	64.031
04-Sep 13:29	2.094	34.683	34.18	0.636	80.107	1.387	103.064	74.123	54.267
04-Sep 13:34	3.05	33.069	33.28	0.996	81.702	1.375	95.468	73.544	69.526
04-Sep 13:39	4.118	32.856	33.917	0.595	80.131	0.921	92.732	67.65	61.066
04-Sep 13:44	3.15	31.038	34.2	0.894	78.913	1.702	93.572	70.875	63.919
04-Sep 13:49	1.602	31.083	33.579	0.727	82.49	1.185	99.559	74.382	56.969
04-Sep 13:54	3.97	31.907	33.846	0.671	75.823	1.485	99.39	72.529	59.39
04-Sep 13:59	3.55	29.9	33.947	0.741	79.177	1.167	95.874	73.129	62.224
04-Sep 14:04	3.853	32.726	33.855	0.624	79.818	1.534	98.425	73.196	59.827
04-Sep 14:09	3.584	32.033	33.798	0.593	75.854	1.226	97.477	76.701	61.214
04-Sep 14:14	2.623	33.728	34.2	0.973	78.359	1.596	96.639	69.583	59.479
04-Sep 14:19	2.519	29.999	34.064	0.807	80.476	0.965	92.772	71.072	69.369
04-Sep 14:24	2.649	32.309	34.2	0.487	81.054	1.22	97.533	75.248	58.253
04-Sep 14:29	2.4	30.639	33.661	0.314	80.637	0.91	91.386	74.776	64.766
04-Sep 14:34	3.228	32.63	33.891	0.758	76.785	1.313	98.825	71.655	68.227

Timestamp	Treated Sweet Water			Thermo Compressor	Vaporisation Chambers				
	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C
04-Sep 14:39	4.165	32.698	34.173	0.787	79.148	1.494	89.099	67.53	70.236
04-Sep 14:44	2.195	33.807	34.179	1.1	79.573	1.282	92.113	77.301	62.631
04-Sep 14:49	3.863	32.953	33.768	0.351	77.481	1.059	101.341	66.903	61.251
04-Sep 14:54	3.598	29.9	33.766	0.593	75.804	1.073	96.781	73.434	64.074
04-Sep 14:59	2.856	33.952	34.01	0.81	77.829	1.371	93.364	75.58	65.312
04-Sep 15:04	2.975	30.795	34.052	0.93	77.655	1.391	86.978	76.752	60.53
04-Sep 15:09	2.683	32.254	33.808	0.532	80.355	1.411	89.436	73.006	62.195
04-Sep 15:14	2.225	34.549	34.081	1.1	74.501	0.9	94.618	74.105	60.731
04-Sep 15:19	2.621	33.812	33.965	0.511	77.357	1.055	93.501	71.432	58.984
04-Sep 15:24	2.919	30.881	33.901	0.573	76.307	1.261	98.174	65.844	64.089
04-Sep 15:29	2.995	33.096	33.881	0.589	77.784	1.333	92.291	78.008	56.541
04-Sep 15:34	2.67	31.004	33.889	0.959	80.215	1.122	93.632	73.318	63.78
04-Sep 15:39	2.761	31.677	34.2	0.52	77.563	1.297	94.184	76.72	55.672
04-Sep 15:44	3.555	30.188	33.687	0.932	76.422	1.205	89.684	70.262	62.29
04-Sep 15:49	2.695	32.735	33.608	0.813	79.11	1.039	92.159	75.148	63.402
04-Sep 15:54	3.295	32.397	34.079	0.738	76.27	1.253	100.924	71.192	60.481
04-Sep 15:59	3.074	33.665	33.809	0.966	80.818	1.299	99.922	73.095	57.618
04-Sep 16:04	2.602	32.583	34.075	0.718	75.208	1.17	86.861	74.992	67.934
04-Sep 16:09	3.434	29.9	33.765	0.573	82.293	0.938	95.71	80.282	63.076
04-Sep 16:14	2.987	30.262	33.784	0.736	80.055	1.005	98.463	74.171	61.078
04-Sep 16:19	2.763	31.094	33.974	0.773	77.835	1.011	95.854	72.097	66.468
04-Sep 16:24	3.614	31.861	33.953	0.613	78.743	1.171	93.489	69.805	65.079
04-Sep 16:29	3.01	35.396	33.813	0.551	77.939	0.927	95.327	72.301	61.72
04-Sep 16:34	3.448	31.645	33.776	0.495	77.054	1.303	87.097	73.79	69.516
04-Sep 16:39	3.248	29.9	33.684	0.726	84.234	1.103	97.723	70.589	60.944
04-Sep 16:44	2.396	31.377	33.489	0.355	78.691	1.343	99.303	77.978	49.56
04-Sep 16:49	3.244	32.62	33.794	0.488	75.933	1.242	96.219	71.715	56.733
04-Sep 16:54	2.926	30.647	33.747	0.343	81.739	1.081	94.076	79.678	61.476
04-Sep 16:59	1.486	30.169	33.66	0.463	77.129	0.991	96.281	71.829	65.865
04-Sep 17:04	2.797	29.975	33.907	0.548	78.648	1.471	91.348	72.674	69.875
04-Sep 17:09	2.151	32.254	33.789	0.224	76.311	1.063	89.832	76.065	61.064
04-Sep 17:14	3.778	32.198	34.109	0.429	76.931	1.234	96.902	69.798	67.87
04-Sep 17:19	2.149	31.407	34.2	0.538	76.817	1.278	90.54	75.188	71.311
04-Sep 17:24	2.712	31.704	34.078	0.721	80.29	1.404	89.406	65.694	62.606
04-Sep 17:29	2.964	30.228	33.806	0.883	79.24	1.274	90.222	74.144	65.29
04-Sep 17:34	2.927	32.738	33.489	0.461	80.249	1.149	98.119	73.649	60.313
04-Sep 17:39	2.382	30.346	34.19	0.884	78.99	1.358	97.094	75.19	65.46
04-Sep 17:44	3.602	31.942	33.821	0.075	80.013	1.126	92.92	75.174	57.107
04-Sep 17:49	2.178	34.45	33.861	0.606	79.967	1.101	98.042	71.343	61.022
04-Sep 17:54	3.572	33.174	33.91	0.337	76.369	1.104	88.688	72.606	62.047
04-Sep 17:59	2.27	33.598	33.869	0.254	78.257	1.095	91.418	74.848	65.275
04-Sep 18:04	2.077	31.368	33.883	0.222	78.549	1.06	91.325	69.185	57.886
04-Sep 18:09	3.033	33.0	33.55	0.016	77.124	1.291	89.149	77.052	56.863
04-Sep 18:14	2.685	32.856	33.818	0.615	74.243	1.123	93.018	70.047	59.531

Timestamp	Treated Sweet Water			Thermo Compressor	Vaporisation Chambers				
	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C
04-Sep 18:19	2.497	30.293	33.657	1.042	78.057	1.148	97.661	72.053	56.45
04-Sep 18:24	1.689	32.842	34.044	-0.081	80.336	1.247	95.529	72.073	62.057
04-Sep 18:29	3.58	30.807	33.552	0.213	77.556	1.032	94.376	70.431	67.793
04-Sep 18:34	2.031	31.378	33.77	0.013	77.822	0.9	86.079	75.932	61.979
04-Sep 18:39	2.954	34.701	33.511	0.768	79.686	0.9	87.656	73.076	56.38
04-Sep 18:44	3.415	32.068	33.996	0.012	76.0	1.014	94.194	75.577	55.358
04-Sep 18:49	3.77	30.311	33.634	0.592	79.523	0.9	97.922	70.517	63.947
04-Sep 18:54	2.432	31.284	34.191	0.571	76.46	1.017	93.191	68.983	63.011
04-Sep 18:59	3.743	32.413	33.712	0.726	78.053	0.9	88.117	72.027	59.993
04-Sep 19:04	2.303	32.256	33.994	0.461	81.295	0.9	91.374	75.571	64.693
04-Sep 19:09	3.232	32.054	33.9	0.714	74.799	1.255	97.18	72.19	56.023
04-Sep 19:14	2.631	31.905	33.773	0.086	76.178	0.9	95.867	74.547	56.282
04-Sep 19:19	2.288	30.624	33.956	0.74	78.662	0.943	88.863	69.677	55.363
04-Sep 19:24	2.552	32.485	33.733	0.726	75.887	0.975	94.766	68.491	55.808
04-Sep 19:29	3.552	32.889	33.637	0.316	77.426	1.257	91.515	74.804	62.941
04-Sep 19:34	2.74	30.89	33.48	0.52	80.035	1.331	93.506	70.477	56.373
04-Sep 19:39	2.608	32.441	33.292	0.382	78.036	1.084	88.348	72.692	57.909
04-Sep 19:44	3.083	32.828	33.879	0.753	79.254	1.376	85.0	75.298	60.409
04-Sep 19:49	2.955	33.779	33.828	0.28	78.58	1.076	85.0	66.174	56.598
04-Sep 19:54	2.049	33.405	33.945	0.592	75.474	0.953	92.248	68.12	58.113
04-Sep 19:59	2.309	31.582	33.623	0.391	78.969	0.9	87.521	71.744	54.699
04-Sep 20:04	2.1	32.128	33.987	0.748	80.392	1.188	90.168	71.305	59.714
04-Sep 20:09	2.207	29.9	33.57	0.211	81.561	1.197	93.432	71.921	62.495
04-Sep 20:14	3.125	32.111	33.876	0.596	75.326	1.146	101.301	68.748	62.731
04-Sep 20:19	2.99	30.486	33.73	0.791	76.045	0.9	91.517	67.603	56.937
04-Sep 20:24	1.155	31.62	33.973	0.336	75.649	1.203	94.594	73.949	57.976
04-Sep 20:29	2.2	33.097	33.632	0.601	78.056	1.023	97.88	70.163	53.682
04-Sep 20:34	2.761	29.9	34.106	0.334	78.107	1.011	99.062	71.088	51.933
04-Sep 20:39	2.647	33.158	34.112	0.387	77.971	1.174	92.612	70.258	60.536
04-Sep 20:44	2.237	30.59	33.951	0.32	77.525	0.988	98.192	67.848	54.509
04-Sep 20:49	2.009	33.645	33.835	0.32	81.547	1.007	93.39	70.996	64.318
04-Sep 20:54	2.846	30.074	33.918	0.242	77.885	0.985	95.187	72.398	63.189
04-Sep 20:59	3.553	29.9	33.742	-0.092	75.767	0.932	93.289	70.596	56.541
04-Sep 21:04	3.973	29.9	33.73	0.393	79.765	1.37	88.249	71.002	56.919
04-Sep 21:09	3.665	29.9	33.388	0.813	77.873	1.104	92.06	71.044	62.007
04-Sep 21:14	2.021	31.272	33.531	-0.025	80.463	1.137	92.461	70.237	52.988
04-Sep 21:19	3.114	29.9	33.852	0.578	77.666	1.062	91.646	66.165	60.848
04-Sep 21:24	2.153	30.411	33.622	-0.1	78.649	1.227	92.66	68.263	61.866
04-Sep 21:29	2.691	29.9	33.819	0.243	76.013	1.005	89.18	73.009	56.478
04-Sep 21:34	2.817	29.9	33.899	0.223	80.39	0.993	92.23	68.964	62.413
04-Sep 21:39	2.621	29.9	33.285	0.385	76.558	1.017	85.0	72.53	63.007
04-Sep 21:44	1.897	31.574	33.762	-0.06	77.077	0.916	85.565	67.532	63.408
04-Sep 21:49	2.882	31.175	33.642	0.467	77.219	0.9	96.678	68.349	57.691
04-Sep 21:54	2.343	32.088	33.642	-0.1	80.807	1.199	91.149	66.21	54.449

	Treated Sweet Water			Thermo Compressor	Vaporisation Chambers				
Timestamp	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C
04-Sep 21:59	2.516	31.159	33.46	-0.005	74.614	1.198	89.66	68.946	61.206
04-Sep 22:04	2.312	29.9	33.754	0.114	76.023	0.9	93.321	76.175	55.587
04-Sep 22:09	2.557	32.301	34.166	0.443	76.774	1.368	87.905	69.968	52.016
04-Sep 22:14	3.092	31.856	33.562	0.05	76.765	1.098	91.689	72.086	60.762
04-Sep 22:19	3.162	31.689	33.797	0.201	79.023	1.258	86.364	71.486	57.132
04-Sep 22:24	2.97	30.379	34.021	-0.1	76.237	1.138	91.859	71.116	57.175
04-Sep 22:29	2.728	33.534	33.844	0.864	77.366	1.436	91.436	67.803	63.255
04-Sep 22:34	2.264	29.9	33.675	0.69	73.914	1.108	93.763	67.038	56.186
04-Sep 22:39	1.701	30.601	33.858	0.58	73.892	1.062	95.229	71.381	57.396
04-Sep 22:44	3.259	34.162	33.879	0.231	76.456	1.038	97.35	71.607	58.778
04-Sep 22:49	2.824	30.876	34.127	-0.1	77.116	1.161	88.829	77.011	49.96
04-Sep 22:54	2.799	31.516	33.877	0.227	76.079	1.127	85.0	74.791	55.929
04-Sep 22:59	1.544	30.506	33.825	0.413	77.482	1.138	96.204	73.005	60.503
04-Sep 23:04	1.624	31.056	33.876	0.347	79.694	0.9	86.179	72.341	57.79
04-Sep 23:09	2.647	30.602	33.502	0.789	78.752	0.918	85.0	70.404	61.694
04-Sep 23:14	2.945	33.376	33.614	0.36	77.348	1.161	91.603	69.913	61.264
04-Sep 23:19	2.189	29.9	33.891	-0.094	75.77	0.9	88.955	69.828	65.013
04-Sep 23:24	2.203	31.971	33.747	0.731	77.051	1.291	90.898	64.252	53.689
04-Sep 23:29	2.276	30.51	33.41	0.491	75.252	1.081	92.399	72.643	61.72
04-Sep 23:34	2.277	32.141	33.671	0.165	77.941	1.014	91.103	72.229	64.597
04-Sep 23:39	1.942	29.9	33.779	-0.1	75.745	1.294	89.415	68.037	67.716
04-Sep 23:44	2.988	29.9	33.857	0.683	79.735	0.9	89.683	72.644	58.94
04-Sep 23:49	3.017	32.779	33.535	0.383	77.082	1.053	96.308	66.206	55.702
04-Sep 23:54	1.629	33.301	33.979	0.165	77.155	0.904	87.065	75.522	52.922
04-Sep 23:59	2.153	29.9	33.686	0.328	75.943	0.966	85.0	69.607	66.735
05-Sep 00:04	3.335	31.786	33.947	-0.055	79.546	0.9	88.568	63.074	49.618
05-Sep 00:09	1.52	30.547	33.566	0.524	80.992	0.9	87.335	64.886	54.896
05-Sep 00:14	2.81	29.9	33.632	0.031	76.766	1.307	85.432	74.012	63.664
05-Sep 00:19	3.44	32.652	33.888	-0.075	74.052	0.9	88.15	67.095	54.379
05-Sep 00:24	2.647	31.884	33.795	0.166	75.544	0.9	85.686	70.323	56.156
05-Sep 00:29	2.725	29.9	33.584	0.102	76.542	1.271	91.514	72.855	47.749
05-Sep 00:34	2.614	29.9	33.922	0.356	78.963	0.99	91.122	70.232	54.037
05-Sep 00:39	1.512	32.489	33.868	-0.019	76.178	1.115	88.615	73.084	59.396
05-Sep 00:44	2.113	29.9	33.918	0.58	80.271	1.269	87.399	66.964	58.298
05-Sep 00:49	2.175	31.499	33.598	0.428	76.218	0.9	85.999	67.455	52.506
05-Sep 00:54	2.576	29.9	33.716	0.028	79.103	1.234	87.352	65.992	65.394
05-Sep 00:59	3.907	30.655	33.631	0.309	77.621	0.9	94.115	73.329	57.931
05-Sep 01:04	1.819	32.483	33.47	0.711	75.717	0.9	93.158	67.489	50.413
05-Sep 01:09	2.268	31.083	33.702	0.614	76.237	0.9	91.845	69.384	57.434
05-Sep 01:14	2.226	29.989	33.851	0.171	77.035	1.101	93.036	71.739	61.082
05-Sep 01:19	2.258	29.9	33.394	0.538	74.974	1.056	85.0	67.271	56.889
05-Sep 01:24	2.381	29.9	33.494	0.384	75.437	1.203	99.017	67.861	56.066
05-Sep 01:29	2.051	31.28	33.737	0.493	76.006	1.093	91.924	64.3	57.902
05-Sep 01:34	2.705	29.9	33.955	0.102	76.293	0.95	87.679	72.608	60.844

Timestamp	Treated Sweet Water			Thermo Compressor	Vaporisation Chambers				
	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C
05-Sep 01:39	1.675	29.9	33.912	-0.1	78.984	0.9	88.611	72.438	62.389
05-Sep 01:44	1.859	29.9	33.2	0.094	78.244	1.087	90.181	67.022	61.935
05-Sep 01:49	2.813	30.593	33.584	0.019	75.431	1.167	87.286	70.007	49.341
05-Sep 01:54	2.85	29.9	33.635	0.411	76.574	0.9	90.023	66.299	53.96
05-Sep 01:59	3.056	31.5	33.987	0.546	74.36	0.9	97.376	70.24	57.532
05-Sep 02:04	2.087	32.228	33.508	0.003	77.135	0.942	88.472	69.72	56.996
05-Sep 02:09	3.361	29.9	34.038	0.213	76.454	0.983	85.975	71.609	59.693
05-Sep 02:14	2.402	31.895	33.655	0.626	78.374	0.914	87.985	68.358	51.021
05-Sep 02:19	2.933	29.9	33.845	0.022	79.929	0.9	95.381	73.614	56.841
05-Sep 02:24	2.354	30.932	33.603	0.41	75.732	0.925	91.119	69.152	63.897
05-Sep 02:29	2.578	31.906	33.906	0.806	78.561	0.986	93.635	63.607	62.368
05-Sep 02:34	1.947	31.855	33.71	0.176	78.562	0.913	93.488	70.442	47.002
05-Sep 02:39	1.29	32.537	33.998	0.287	78.659	1.16	94.895	71.304	60.566
05-Sep 02:44	2.494	29.9	33.487	0.217	74.044	1.146	102.758	67.323	63.157
05-Sep 02:49	3.478	31.685	33.9	0.475	78.571	1.09	85.0	68.942	52.212
05-Sep 02:54	2.743	30.796	33.533	0.469	78.486	1.42	87.526	68.04	57.94
05-Sep 02:59	2.331	30.447	33.467	0.143	74.99	1.104	85.0	64.973	55.301
05-Sep 03:04	1.945	29.9	33.695	0.559	78.305	0.993	86.371	70.367	59.572
05-Sep 03:09	2.305	31.116	34.031	0.335	78.805	1.035	86.543	72.12	52.242
05-Sep 03:14	2.19	31.623	33.607	0.617	75.014	1.004	85.0	71.335	58.624
05-Sep 03:19	1.816	29.927	33.708	0.118	73.99	0.982	93.916	74.868	63.68
05-Sep 03:24	3.204	32.01	33.39	0.001	79.369	1.11	90.169	76.098	64.032
05-Sep 03:29	2.723	30.059	33.852	0.591	73.687	0.9	90.405	72.242	59.386
05-Sep 03:34	2.103	30.559	33.973	0.56	77.308	1.054	85.0	67.509	59.67
05-Sep 03:39	3.406	33.113	34.11	-0.1	77.559	1.038	90.892	68.58	53.112
05-Sep 03:44	3.11	30.059	33.745	0.078	75.223	0.9	92.199	66.5	61.854
05-Sep 03:49	1.215	31.386	33.637	0.568	74.429	1.147	90.656	67.85	66.13
05-Sep 03:54	2.52	30.004	33.819	0.057	75.681	0.9	85.0	71.152	67.026
05-Sep 03:59	1.529	30.882	33.418	0.055	77.457	1.025	95.279	71.421	62.188
05-Sep 04:04	2.376	31.691	33.761	0.76	75.843	0.9	100.255	76.114	55.728
05-Sep 04:09	2.782	30.412	33.544	-0.004	78.424	1.147	95.626	68.394	61.149
05-Sep 04:14	3.275	29.9	33.713	0.497	74.662	1.177	89.121	72.476	57.037
05-Sep 04:19	2.601	32.042	33.733	0.66	80.476	0.941	98.869	74.153	61.574
05-Sep 04:24	3.149	29.9	33.508	0.423	77.978	0.9	86.093	70.725	54.451
05-Sep 04:29	3.044	29.9	33.631	0.098	77.821	1.328	93.744	71.979	62.515
05-Sep 04:34	1.77	33.783	34.009	-0.018	75.403	0.9	94.054	70.942	48.531
05-Sep 04:39	1.589	32.473	33.887	0.532	77.969	0.933	88.483	70.014	55.009
05-Sep 04:44	2.884	29.9	33.448	1.002	80.017	1.434	96.788	70.084	56.361
05-Sep 04:49	1.961	31.48	33.695	0.015	78.722	0.953	95.503	66.953	53.293
05-Sep 04:54	1.028	29.9	33.44	0.151	78.801	0.9	88.457	72.302	55.538
05-Sep 04:59	2.674	30.32	33.623	0.74	79.437	1.211	85.0	69.897	52.956
05-Sep 05:04	2.585	32.316	33.729	0.357	81.071	1.134	89.689	72.463	59.721
05-Sep 05:09	3.248	32.569	33.773	0.092	73.663	1.142	102.054	68.005	54.997
05-Sep 05:14	2.058	30.114	33.649	-0.095	75.436	1.199	85.0	76.724	61.463

Timestamp	Treated Sweet Water			Thermo Compressor	Vaporisation Chambers				
	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C
05-Sep 05:19	2.276	34.161	33.657	0.485	76.879	0.9	96.025	70.553	56.377
05-Sep 05:24	2.992	32.398	34.06	0.08	78.34	0.96	101.773	76.212	57.962
05-Sep 05:29	1.734	30.082	33.787	-0.1	76.511	0.928	95.061	69.238	61.617
05-Sep 05:34	3.201	29.9	33.644	0.486	77.882	0.9	89.187	67.081	57.744
05-Sep 05:39	2.484	31.335	33.593	0.484	76.967	1.287	95.933	72.066	52.542
05-Sep 05:44	3.163	31.454	33.565	0.478	77.802	0.981	96.973	74.919	60.277
05-Sep 05:49	1.739	31.577	33.62	0.628	76.074	0.9	91.302	76.009	57.593
05-Sep 05:54	2.381	31.756	33.543	-0.1	79.115	1.058	90.896	72.189	58.916
05-Sep 05:59	3.653	30.503	33.658	-0.1	75.757	0.9	97.996	74.579	59.177
05-Sep 06:04	2.705	31.953	33.548	0.578	78.038	0.9	91.949	71.586	63.611
05-Sep 06:09	3.113	33.498	33.722	0.635	78.672	1.292	97.952	72.487	60.24
05-Sep 06:14	2.497	31.799	33.881	0.664	78.716	0.947	86.184	73.331	58.082
05-Sep 06:19	3.325	30.794	33.934	0.508	78.11	1.064	92.868	70.219	60.946
05-Sep 06:24	2.585	30.524	34.2	0.44	76.974	1.002	95.814	69.993	64.851
05-Sep 06:29	3.495	30.71	33.922	0.708	79.167	1.025	91.828	70.101	54.691
05-Sep 06:34	3.124	31.294	33.761	0.612	80.187	0.9	89.172	66.953	63.519
05-Sep 06:39	2.673	31.621	33.507	0.385	78.512	1.167	92.809	69.685	55.291
05-Sep 06:44	1.484	30.622	33.701	0.88	78.192	1.001	95.428	71.938	60.398
05-Sep 06:49	2.916	29.9	33.692	1.028	77.709	1.144	92.71	71.471	61.412
05-Sep 06:54	3.398	31.811	34.2	0.606	77.58	0.9	93.879	71.717	59.346
05-Sep 06:59	3.622	31.641	34.01	0.18	77.642	1.186	96.299	70.456	60.559
05-Sep 07:04	3.355	34.618	34.015	0.2	74.588	0.9	92.634	74.831	58.873
05-Sep 07:09	2.518	32.713	33.946	0.17	79.287	1.1	87.951	71.624	56.975
05-Sep 07:14	3.345	32.738	33.832	0.417	76.658	1.034	89.117	71.091	58.799
05-Sep 07:19	2.357	31.308	33.759	0.371	78.311	1.231	95.15	72.447	56.553
05-Sep 07:24	2.632	30.034	33.685	0.762	80.825	0.949	88.315	73.262	55.055
05-Sep 07:29	2.659	29.9	33.507	0.717	77.308	1.407	90.083	68.724	61.534
05-Sep 07:34	3.245	32.488	34.11	0.503	73.973	0.992	94.061	77.701	57.031
05-Sep 07:39	2.833	33.942	33.587	0.481	76.513	1.401	95.178	71.104	60.194
05-Sep 07:44	2.65	30.292	33.844	1.1	79.146	1.151	91.906	70.757	61.224
05-Sep 07:49	3.581	32.977	33.694	0.87	75.897	0.9	96.377	71.797	66.592
05-Sep 07:54	2.566	30.213	33.531	0.374	79.476	0.9	97.038	73.201	63.43
05-Sep 07:59	2.518	33.179	33.843	0.228	82.196	0.934	91.539	63.473	57.886
05-Sep 08:04	3.062	29.9	33.859	0.916	80.845	0.982	92.242	76.504	57.469
05-Sep 08:09	2.862	30.209	33.797	0.429	76.156	1.079	91.963	65.715	57.722
05-Sep 08:14	3.175	31.434	34.2	0.119	81.125	0.968	92.14	70.163	53.286
05-Sep 08:19	2.826	31.154	33.733	0.108	77.992	1.153	103.805	68.166	62.835
05-Sep 08:24	2.77	29.9	33.832	0.911	76.707	0.992	90.871	77.733	58.286
05-Sep 08:29	3.418	31.128	33.77	0.56	79.041	1.224	97.53	69.786	63.971
05-Sep 08:34	2.61	31.459	33.704	0.25	77.948	0.9	96.786	72.3	66.045
05-Sep 08:39	2.583	30.852	33.839	0.575	79.997	0.998	106.47	75.132	61.555
05-Sep 08:44	3.355	31.387	33.852	0.838	83.396	1.048	98.413	72.839	59.274
05-Sep 08:49	3.393	29.917	33.732	0.543	77.19	1.041	96.194	75.532	72.1
05-Sep 08:54	2.093	30.273	33.799	0.762	80.484	0.928	95.746	71.863	57.806

	Treated Sweet Water			Thermo Compressor		Vaporisation Chambers				
Timestamp	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C	
05-Sep 08:59	2.108	32.504	33.764	0.356	75.813	1.572	94.99	77.382	63.119	
05-Sep 09:04	2.56	33.655	34.019	-0.1	78.892	1.012	96.577	73.557	61.706	
05-Sep 09:09	2.474	30.875	33.786	0.965	77.149	1.042	90.895	72.226	66.168	
05-Sep 09:14	2.58	30.702	34.02	0.65	78.79	0.9	96.235	74.254	64.453	
05-Sep 09:19	2.712	34.863	34.055	0.476	78.637	1.208	103.122	73.963	66.11	
05-Sep 09:24	3.645	31.858	33.936	0.769	77.328	1.116	99.975	73.801	57.294	
05-Sep 09:29	2.777	32.086	33.459	0.924	79.248	1.592	85.0	73.997	58.142	
05-Sep 09:34	3.137	30.576	33.992	0.62	80.111	1.159	87.977	77.425	57.819	
05-Sep 09:39	4.591	29.9	34.2	0.124	75.166	1.267	96.615	70.285	63.177	
05-Sep 09:44	2.451	32.064	33.95	0.697	78.687	1.134	92.848	70.698	60.861	
05-Sep 09:49	3.563	29.9	34.056	0.896	78.631	0.95	90.076	71.74	56.686	
05-Sep 09:54	3.035	30.305	33.691	0.92	75.732	0.918	89.256	71.702	63.547	
05-Sep 09:59	1.625	33.312	33.879	0.56	78.123	1.093	93.41	73.274	52.511	
05-Sep 10:04	2.321	31.472	34.021	0.462	81.027	0.9	95.9	65.205	62.544	
05-Sep 10:09	2.646	30.911	33.601	0.417	78.111	0.9	92.578	75.699	59.994	
05-Sep 10:14	3.883	33.112	33.97	0.796	80.391	1.225	91.636	70.438	58.424	
05-Sep 10:19	3.607	30.595	34.2	0.245	79.23	1.273	94.484	73.871	62.637	
05-Sep 10:24	2.106	32.91	34.2	0.612	80.832	0.9	92.582	69.915	58.836	
05-Sep 10:29	3.157	32.295	33.74	1.076	76.575	1.272	91.493	71.439	60.833	
05-Sep 10:34	2.633	31.897	33.979	0.811	76.154	1.525	92.874	70.577	61.81	
05-Sep 10:39	3.443	32.974	33.979	0.429	79.438	1.476	96.67	74.532	62.811	
05-Sep 10:44	2.429	32.654	33.797	0.524	80.565	1.408	93.894	72.523	59.59	
05-Sep 10:49	2.518	31.718	33.92	0.805	79.006	0.958	99.698	78.363	63.488	
05-Sep 10:54	2.37	29.9	33.982	0.579	83.068	1.347	96.069	75.199	60.645	
05-Sep 10:59	2.971	33.551	33.879	1.1	75.302	1.304	97.568	70.878	66.242	
05-Sep 11:04	3.346	31.123	33.877	0.071	75.8	0.9	93.562	75.089	61.101	
05-Sep 11:09	2.435	31.234	34.023	0.678	75.364	1.468	93.438	72.078	64.111	
05-Sep 11:14	2.361	31.585	33.768	0.595	78.969	1.239	91.89	67.523	62.164	
05-Sep 11:19	2.6	31.302	33.713	0.39	75.327	1.049	102.26	76.073	60.249	
05-Sep 11:24	4.114	35.542	34.013	0.827	81.159	1.264	89.629	73.178	59.568	
05-Sep 11:29	2.424	30.653	34.043	0.602	79.863	1.481	95.801	67.816	61.17	
05-Sep 11:34	2.693	31.784	33.598	0.613	81.12	1.18	96.123	74.469	61.054	
05-Sep 11:39	3.258	32.674	33.925	0.322	81.17	1.341	89.198	71.243	62.795	
05-Sep 11:44	3.384	33.069	33.992	0.272	78.053	1.434	87.664	75.059	65.376	
05-Sep 11:49	2.347	30.742	33.815	0.104	78.56	1.471	102.967	75.495	67.435	
05-Sep 11:54	3.126	36.095	33.976	0.91	77.617	1.326	96.364	73.968	64.585	
05-Sep 11:59	3.606	34.704	33.619	0.653	79.559	1.284	100.028	70.303	60.764	
05-Sep 12:04	4.069	31.581	33.872	0.854	80.112	1.291	104.082	77.259	68.187	
05-Sep 12:09	2.893	31.752	34.021	1.007	79.99	1.346	88.089	78.637	63.285	
05-Sep 12:14	3.345	32.41	33.816	0.443	77.807	1.349	96.246	76.156	61.79	
05-Sep 12:19	3.058	30.937	33.835	1.074	76.016	1.058	92.38	75.268	65.212	
05-Sep 12:24	2.087	33.547	33.78	-0.1	77.954	1.438	97.477	71.662	68.189	
05-Sep 12:29	3.61	33.612	33.972	0.769	81.721	1.28	93.73	74.904	60.283	
05-Sep 12:34	2.92	32.564	33.821	0.944	82.911	1.205	92.197	67.952	64.838	

Timestamp	Treated Sweet Water			Thermo Compressor	Vaporisation Chambers				
	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C
05-Sep 12:39	3.648	32.83	33.93	1.0	80.393	1.517	98.884	69.909	63.91
05-Sep 12:44	3.152	32.88	33.788	0.798	81.171	1.054	96.272	71.653	68.887
05-Sep 12:49	3.84	33.973	33.741	0.942	77.651	1.162	99.847	69.541	62.327
05-Sep 12:54	3.046	33.872	33.715	0.208	83.43	1.481	97.884	78.269	60.504
05-Sep 12:59	3.794	29.9	33.733	0.485	77.845	1.507	97.652	76.28	66.358
05-Sep 13:04	3.341	32.485	33.96	0.768	78.112	1.223	97.047	70.706	61.83
05-Sep 13:09	3.437	32.338	33.97	0.157	81.221	0.964	98.341	74.924	61.959
05-Sep 13:14	2.439	30.435	34.033	0.694	81.152	1.27	92.644	76.201	65.078
05-Sep 13:19	3.126	35.114	33.782	0.583	77.835	1.51	89.522	77.035	63.252
05-Sep 13:24	2.605	29.9	33.65	0.471	80.83	1.4	97.06	73.589	56.927
05-Sep 13:29	3.362	33.76	33.8	0.655	79.201	1.377	97.634	69.873	66.661
05-Sep 13:34	3.576	33.11	34.022	0.82	78.755	0.93	94.725	69.706	65.662
05-Sep 13:39	2.192	32.844	33.773	1.066	79.238	1.26	93.586	75.125	58.511
05-Sep 13:44	3.373	30.294	34.2	0.664	79.836	1.518	96.331	74.769	64.645
05-Sep 13:49	3.034	32.59	33.791	0.813	80.202	1.104	98.838	72.611	64.803
05-Sep 13:54	2.419	34.212	33.923	0.736	79.119	1.376	94.923	71.832	60.553
05-Sep 13:59	2.924	33.677	33.906	0.836	79.312	1.5	88.188	72.701	64.422
05-Sep 14:04	2.618	31.717	33.937	1.1	80.073	1.148	97.931	71.854	58.752
05-Sep 14:09	3.087	32.546	33.728	0.621	80.662	1.359	92.908	73.53	64.661
05-Sep 14:14	1.938	35.203	33.794	0.644	79.943	1.211	90.554	80.438	59.911
05-Sep 14:19	3.203	33.731	33.612	0.849	80.919	1.26	97.167	71.085	62.071
05-Sep 14:24	1.575	30.944	33.692	0.383	80.732	1.366	86.874	69.067	60.643
05-Sep 14:29	2.762	34.395	33.846	0.861	81.055	1.593	95.669	73.509	57.022
05-Sep 14:34	3.411	33.589	34.012	1.034	82.583	1.352	94.731	70.59	55.371
05-Sep 14:39	3.415	32.483	33.616	0.593	80.829	1.127	95.604	69.871	69.99
05-Sep 14:44	2.426	32.206	33.939	0.781	79.92	0.987	93.15	71.812	64.165
05-Sep 14:49	2.653	31.594	34.076	0.448	78.514	1.6	87.487	79.076	63.01
05-Sep 14:54	3.337	32.882	33.959	0.493	78.367	1.259	93.47	71.93	58.846
05-Sep 14:59	3.164	32.116	33.682	0.384	80.428	1.308	98.234	67.795	64.991
05-Sep 15:04	2.677	31.039	33.728	0.421	82.219	1.672	85.0	70.95	72.1
05-Sep 15:09	2.839	32.295	33.952	0.304	80.808	1.218	92.866	75.908	58.5
05-Sep 15:14	2.942	32.793	34.049	0.702	76.909	1.383	93.371	73.79	56.627
05-Sep 15:19	3.349	34.473	34.099	0.745	78.3	1.116	99.531	71.162	57.806
05-Sep 15:24	3.174	34.938	33.756	0.984	79.259	1.084	92.429	72.757	59.064
05-Sep 15:29	3.629	30.795	33.751	1.002	75.567	1.429	92.753	63.648	57.442
05-Sep 15:34	2.998	30.108	33.718	0.754	80.885	1.098	88.937	65.777	61.93
05-Sep 15:39	3.211	30.957	33.505	0.813	79.143	1.291	95.777	78.82	55.793
05-Sep 15:44	3.061	35.754	33.976	1.1	80.006	0.9	96.944	74.631	67.573
05-Sep 15:49	2.864	30.378	33.977	0.641	82.821	1.368	98.091	75.74	68.087
05-Sep 15:54	3.163	31.643	33.9	0.08	78.912	0.976	92.323	80.502	59.99
05-Sep 15:59	3.579	34.381	33.985	0.492	77.907	1.185	97.505	66.696	63.92
05-Sep 16:04	3.315	34.96	33.737	0.556	77.354	1.053	92.36	73.389	65.678
05-Sep 16:09	3.63	31.153	33.648	0.957	78.583	1.051	95.586	72.55	63.976
05-Sep 16:14	3.686	34.078	33.896	0.518	76.987	0.9	97.053	69.174	59.227

Timestamp	Treated Sweet Water			Thermo Compressor	Vaporisation Chambers				
	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C
05-Sep 16:19	2.295	30.035	34.021	0.692	78.696	1.251	100.626	73.689	68.304
05-Sep 16:24	1.394	31.503	34.061	1.1	80.211	1.282	88.051	70.852	60.117
05-Sep 16:29	3.366	34.365	34.022	0.079	79.719	0.95	96.555	74.834	60.826
05-Sep 16:34	3.203	29.9	34.063	0.865	82.447	0.909	96.154	71.345	66.926
05-Sep 16:39	3.437	32.845	34.2	0.851	82.528	1.248	92.806	75.278	67.372
05-Sep 16:44	4.243	32.0	33.819	1.079	78.9	1.332	89.254	74.672	60.628
05-Sep 16:49	2.517	32.442	33.761	0.513	78.668	1.482	88.154	67.448	64.603
05-Sep 16:54	3.171	31.047	33.837	0.511	78.473	1.608	100.444	73.504	63.98
05-Sep 16:59	2.001	33.615	34.2	1.067	83.235	0.994	92.36	68.762	61.934
05-Sep 17:04	2.792	32.516	33.823	0.611	81.894	1.155	90.672	70.059	59.213
05-Sep 17:09	3.339	33.773	34.105	0.397	78.186	1.146	97.512	75.296	53.528
05-Sep 17:14	3.27	32.799	33.889	0.215	77.365	1.396	90.804	69.663	60.859
05-Sep 17:19	2.705	33.346	33.697	0.936	79.879	0.91	97.786	69.547	64.714
05-Sep 17:24	2.786	32.307	33.847	0.36	74.699	1.07	95.053	68.574	55.275
05-Sep 17:29	2.161	29.963	33.762	0.924	76.407	1.186	92.091	69.694	58.909
05-Sep 17:34	1.586	32.256	33.943	0.891	79.364	0.9	95.631	77.497	66.211
05-Sep 17:39	3.193	29.9	34.2	0.348	82.01	0.928	96.028	75.255	67.065
05-Sep 17:44	3.332	30.289	33.949	0.461	79.643	1.212	93.42	69.646	56.247
05-Sep 17:49	2.132	32.75	33.948	0.638	80.144	1.113	92.218	75.026	62.825
05-Sep 17:54	3.528	32.016	33.869	0.516	75.956	1.178	90.038	72.864	63.89
05-Sep 17:59	2.999	30.539	33.887	0.691	75.933	1.331	96.13	64.246	60.22
05-Sep 18:04	3.179	30.68	33.688	0.617	76.457	1.169	94.517	72.93	57.436
05-Sep 18:09	2.249	37.233	33.851	0.741	80.112	1.112	92.445	72.307	63.897
05-Sep 18:14	2.863	33.128	33.84	0.828	79.699	1.102	88.234	69.332	61.375
05-Sep 18:19	2.592	30.445	33.414	0.438	77.532	1.045	99.199	71.886	55.995
05-Sep 18:24	2.879	32.01	33.973	0.465	78.62	1.189	90.6	71.384	63.723
05-Sep 18:29	2.883	32.851	33.651	0.28	80.473	1.063	90.126	65.359	56.142
05-Sep 18:34	2.177	30.611	34.137	0.648	77.787	1.012	100.2	74.747	55.959
05-Sep 18:39	2.906	29.9	33.699	0.051	77.83	0.9	94.375	78.207	57.906
05-Sep 18:44	2.27	33.862	33.786	1.1	80.937	1.379	96.761	71.651	67.374
05-Sep 18:49	2.231	33.48	33.648	0.483	76.978	1.024	87.349	71.892	60.862
05-Sep 18:54	1.651	32.266	33.487	0.461	78.719	0.9	97.061	75.099	57.574
05-Sep 18:59	2.8	31.1	33.618	0.597	79.319	1.207	85.955	69.886	60.077
05-Sep 19:04	3.389	31.983	33.808	0.713	83.375	1.014	97.057	72.542	70.416
05-Sep 19:09	3.558	29.9	33.836	0.702	79.716	0.908	91.339	70.281	54.177
05-Sep 19:14	2.422	33.802	33.619	0.044	77.134	1.199	98.946	69.872	58.803
05-Sep 19:19	2.858	31.186	33.769	0.767	78.988	1.442	89.84	72.53	64.964
05-Sep 19:24	3.169	30.784	34.161	0.601	78.78	1.105	95.828	64.783	60.502
05-Sep 19:29	2.278	31.148	33.444	1.1	75.954	1.043	88.757	69.305	65.382
05-Sep 19:34	4.106	33.109	33.869	0.232	80.157	1.051	91.365	76.396	59.822
05-Sep 19:39	3.177	32.177	34.056	0.3	80.921	1.085	88.74	68.747	51.425
05-Sep 19:44	2.0	35.822	34.135	0.089	78.646	1.03	92.488	73.041	59.648
05-Sep 19:49	2.971	33.636	34.128	0.471	76.74	0.9	90.859	68.742	61.174
05-Sep 19:54	3.117	32.222	34.063	0.682	78.891	1.02	104.349	77.444	59.184

Timestamp	Treated Sweet Water			Thermo Compressor	Vaporisation Chambers				
	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C
05-Sep 19:59	1.848	29.9	34.016	0.704	81.504	1.066	91.534	68.556	63.036
05-Sep 20:04	3.511	32.407	33.769	0.384	76.955	0.9	88.579	68.52	57.22
05-Sep 20:09	1.865	31.46	33.646	0.63	77.019	0.9	90.008	72.519	60.218
05-Sep 20:14	2.052	29.9	33.724	0.875	75.413	1.236	85.0	73.956	61.686
05-Sep 20:19	3.116	31.439	33.816	0.402	83.203	0.9	91.033	72.887	60.294
05-Sep 20:24	1.609	31.548	34.2	0.172	78.948	1.069	89.377	74.021	58.391
05-Sep 20:29	1.035	32.013	33.791	0.767	78.238	1.34	85.0	72.225	62.968
05-Sep 20:34	2.152	30.771	33.582	0.063	75.233	1.515	92.158	73.063	62.43
05-Sep 20:39	2.666	32.465	33.636	1.064	78.705	1.156	94.632	71.667	63.541
05-Sep 20:44	2.624	30.564	33.562	0.425	79.015	1.305	96.675	75.94	64.327
05-Sep 20:49	2.74	31.814	33.955	0.182	75.99	0.9	89.973	73.085	61.397
05-Sep 20:54	2.802	29.9	33.947	0.38	78.073	1.203	99.087	76.433	59.114
05-Sep 20:59	2.509	32.403	33.848	0.447	79.531	0.9	91.718	67.925	66.68
05-Sep 21:04	2.339	33.601	33.594	0.898	76.893	1.28	90.192	68.208	61.497
05-Sep 21:09	2.256	29.9	33.702	0.44	76.261	1.108	86.196	73.429	62.974
05-Sep 21:14	2.506	31.402	33.534	0.835	75.067	0.9	93.666	70.538	62.696
05-Sep 21:19	2.76	34.649	33.591	0.228	73.8	1.024	85.0	68.511	56.514
05-Sep 21:24	2.383	30.801	33.759	0.213	80.392	1.132	94.359	72.144	67.004
05-Sep 21:29	1.827	29.9	33.587	0.399	76.755	0.921	88.691	71.128	57.901
05-Sep 21:34	3.054	31.186	33.95	0.358	74.416	0.9	93.626	69.245	58.922
05-Sep 21:39	3.28	30.076	33.735	0.584	75.297	0.9	87.643	71.564	60.88
05-Sep 21:44	4.374	33.005	33.678	0.371	75.833	0.9	91.372	70.115	58.666
05-Sep 21:49	2.275	29.9	34.012	-0.1	78.767	1.216	85.0	70.706	65.891
05-Sep 21:54	2.595	29.9	34.0	0.556	77.377	0.913	91.672	72.417	59.038
05-Sep 21:59	2.429	32.168	33.489	0.335	75.316	0.971	86.746	72.802	63.674
05-Sep 22:04	3.765	29.9	33.635	0.27	77.278	0.9	91.51	68.53	68.06
05-Sep 22:09	3.235	31.832	33.695	0.184	74.543	0.9	88.112	69.128	57.481
05-Sep 22:14	1.831	31.329	33.775	0.433	81.618	0.983	90.774	68.583	61.948
05-Sep 22:19	1.933	31.065	33.506	0.53	76.934	1.18	93.113	75.287	59.175
05-Sep 22:24	2.415	31.692	33.589	0.45	76.063	1.231	85.0	68.665	53.121
05-Sep 22:29	2.22	30.489	33.481	0.919	78.102	1.302	85.0	65.136	57.646
05-Sep 22:34	2.126	31.736	33.574	0.531	73.922	1.223	92.468	72.134	56.158
05-Sep 22:39	3.04	29.9	33.812	0.256	72.527	0.904	93.072	66.116	52.789
05-Sep 22:44	2.789	29.9	33.592	0.5	74.355	1.146	101.343	68.939	64.102
05-Sep 22:49	2.931	31.799	33.833	-0.027	76.458	0.976	91.777	70.165	58.974
05-Sep 22:54	2.552	32.611	33.488	0.497	73.428	0.9	87.089	69.367	55.02
05-Sep 22:59	3.043	30.418	33.787	0.252	75.067	0.9	85.09	67.206	61.599
05-Sep 23:04	2.42	30.035	33.735	0.918	77.289	1.019	91.926	73.905	50.066
05-Sep 23:09	2.725	30.992	33.695	0.048	75.535	1.149	85.0	71.28	60.317
05-Sep 23:14	2.073	29.9	34.081	0.011	76.69	0.9	87.655	70.787	57.189
05-Sep 23:19	3.056	32.352	33.465	0.278	76.414	0.983	85.0	70.508	58.307
05-Sep 23:24	3.075	32.113	33.486	0.126	77.465	0.9	94.297	68.312	60.194
05-Sep 23:29	2.748	31.489	34.125	0.047	78.476	1.227	94.571	69.324	63.509
05-Sep 23:34	2.697	29.9	33.303	0.403	77.433	1.159	90.54	75.959	52.62

Timestamp	Treated Sweet Water			Thermo Compressor		Vaporisation Chambers				
	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C	
05-Sep 23:39	3.201	29.9	33.645	0.025	75.636	0.979	88.695	67.97	52.659	
05-Sep 23:44	2.595	29.9	33.91	0.216	78.083	0.9	86.373	70.928	56.012	
05-Sep 23:49	1.511	30.039	33.563	0.228	74.061	1.142	90.196	69.927	56.524	
05-Sep 23:54	2.551	33.231	33.771	-0.054	73.55	1.513	85.0	74.339	53.349	
05-Sep 23:59	2.112	30.014	33.748	0.352	76.341	0.9	87.647	66.303	67.393	
06-Sep 00:04	2.625	31.558	33.39	0.687	78.93	1.145	85.0	70.761	52.673	
06-Sep 00:09	1.961	32.342	33.665	0.132	78.431	1.035	96.861	77.126	59.551	
06-Sep 00:14	3.494	31.687	33.781	-0.009	77.968	1.336	85.71	73.136	70.39	
06-Sep 00:19	3.117	31.061	33.445	0.28	76.87	1.023	92.787	67.549	57.613	
06-Sep 00:24	2.715	29.9	33.677	0.726	80.007	1.147	87.424	69.477	56.646	
06-Sep 00:29	1.316	30.505	33.441	0.511	77.374	0.9	86.101	69.393	54.675	
06-Sep 00:34	2.293	32.59	33.524	-0.1	75.556	0.995	90.418	71.72	56.061	
06-Sep 00:39	2.485	33.288	34.008	0.64	74.851	1.183	92.102	72.011	54.25	
06-Sep 00:44	1.737	31.682	33.969	0.256	76.79	0.9	96.114	67.164	58.048	
06-Sep 00:49	2.416	31.664	34.013	-0.021	77.253	0.902	88.751	72.171	64.605	
06-Sep 00:54	2.978	29.9	33.637	0.307	75.529	1.022	85.759	72.003	53.263	
06-Sep 00:59	2.465	30.602	33.905	-0.052	80.013	0.9	89.624	66.934	58.407	
06-Sep 01:04	2.28	29.9	34.016	0.325	74.753	1.022	91.779	68.634	55.293	
06-Sep 01:09	2.808	29.9	33.628	0.43	76.188	1.073	92.302	74.319	57.505	
06-Sep 01:14	2.402	31.358	33.914	0.259	75.051	1.011	85.0	71.768	54.219	
06-Sep 01:19	2.427	33.542	33.622	0.23	78.452	1.02	97.855	69.123	60.189	
06-Sep 01:24	2.64	30.467	33.668	0.632	73.222	0.985	85.0	72.664	58.269	
06-Sep 01:29	3.004	30.842	33.54	0.155	77.547	1.206	89.84	70.342	52.927	
06-Sep 01:34	1.938	33.581	33.854	-0.1	75.66	1.043	96.635	69.395	65.607	
06-Sep 01:39	1.978	29.9	33.763	0.469	75.182	0.9	91.077	70.738	61.48	
06-Sep 01:44	2.055	32.359	33.692	0.573	76.642	1.116	86.665	73.015	59.737	
06-Sep 01:49	2.604	30.523	33.59	-0.066	74.582	1.006	90.891	64.542	51.284	
06-Sep 01:54	2.021	30.919	33.952	-0.044	74.463	0.9	85.0	70.438	52.308	
06-Sep 01:59	2.052	31.38	33.441	0.102	77.166	1.08	90.745	70.19	62.268	
06-Sep 02:04	2.567	29.9	33.714	0.848	74.984	0.9	90.55	72.564	58.268	
06-Sep 02:09	1.47	30.787	34.011	0.226	77.862	1.33	87.555	73.899	58.25	
06-Sep 02:14	2.999	32.472	33.649	0.81	76.42	0.9	87.262	73.711	59.993	
06-Sep 02:19	2.361	33.697	33.696	0.209	77.092	0.9	85.974	68.621	64.136	
06-Sep 02:24	2.799	31.472	33.429	0.337	78.678	1.061	87.144	72.359	55.025	
06-Sep 02:29	1.336	29.9	33.846	0.164	83.18	0.9	94.768	75.444	59.731	
06-Sep 02:34	1.937	30.75	33.399	0.315	77.104	1.215	87.258	67.463	59.958	
06-Sep 02:39	2.799	32.695	33.699	0.279	77.52	1.122	85.924	63.167	53.577	
06-Sep 02:44	2.899	31.148	33.582	0.561	74.581	0.937	88.518	72.017	56.164	
06-Sep 02:49	3.416	30.683	33.516	0.323	76.067	1.042	91.948	71.439	63.169	
06-Sep 02:54	1.958	30.038	33.704	0.299	78.203	0.95	86.437	74.044	54.879	
06-Sep 02:59	2.36	30.949	33.546	0.47	76.588	0.9	86.375	70.607	60.224	
06-Sep 03:04	1.75	30.143	33.978	-0.026	77.364	0.9	88.237	66.45	60.399	
06-Sep 03:09	2.257	32.731	33.901	0.684	76.537	1.25	93.032	69.137	53.461	
06-Sep 03:14	2.705	29.9	33.887	0.73	76.09	1.17	93.028	71.676	51.465	

	Treated Sweet Water			Thermo Compressor		Vaporisation Chambers				
Timestamp	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C	
06-Sep 03:19	1.384	31.281	33.785	0.246	77.179	0.928	93.526	67.262	60.161	
06-Sep 03:24	2.982	29.9	33.776	0.864	77.744	1.119	86.038	72.016	58.674	
06-Sep 03:29	3.593	30.813	33.751	0.349	74.466	0.9	89.409	70.007	61.492	
06-Sep 03:34	1.965	30.752	33.875	0.452	78.082	1.011	85.0	69.609	65.227	
06-Sep 03:39	2.435	31.249	33.66	0.633	78.973	1.138	87.416	72.593	56.608	
06-Sep 03:44	1.341	31.906	33.701	0.214	79.931	0.991	101.376	67.46	62.519	
06-Sep 03:49	2.896	31.389	33.659	-0.1	77.997	0.977	91.105	68.481	48.813	
06-Sep 03:54	2.192	29.9	33.711	0.619	75.489	0.9	86.441	68.894	56.391	
06-Sep 03:59	2.402	29.9	33.844	0.285	78.938	0.9	89.621	70.751	55.7	
06-Sep 04:04	2.161	31.673	33.808	0.656	78.062	0.9	91.885	71.701	62.326	
06-Sep 04:09	4.014	31.408	33.797	0.449	76.602	1.211	85.0	67.533	62.72	
06-Sep 04:14	2.077	31.005	33.656	0.121	79.511	1.365	91.55	69.466	57.546	
06-Sep 04:19	2.315	30.82	33.582	0.554	77.199	1.173	86.335	60.494	59.364	
06-Sep 04:24	2.599	31.325	33.637	0.473	74.654	0.971	98.373	69.916	57.563	
06-Sep 04:29	2.833	32.699	33.723	0.406	74.662	1.127	95.917	72.687	58.322	
06-Sep 04:34	2.629	29.9	33.384	0.486	78.199	0.9	88.16	72.178	60.831	
06-Sep 04:39	3.781	34.373	33.795	0.929	75.413	1.1	92.16	67.125	59.807	
06-Sep 04:44	2.224	30.804	33.782	0.684	78.091	1.21	91.094	71.945	55.724	
06-Sep 04:49	2.756	30.969	33.981	0.322	79.325	0.9	85.0	76.681	58.152	
06-Sep 04:54	4.057	31.227	33.702	0.041	80.079	1.002	92.625	69.276	58.641	
06-Sep 04:59	2.925	31.916	33.693	0.176	76.095	0.996	95.403	71.184	63.583	
06-Sep 05:04	2.31	30.746	33.937	0.637	74.436	1.112	91.939	68.33	50.127	
06-Sep 05:09	2.908	32.954	33.879	0.498	77.255	1.032	102.366	74.77	57.093	
06-Sep 05:14	2.223	34.693	33.78	1.011	79.199	0.9	86.906	72.566	60.277	
06-Sep 05:19	2.875	32.978	33.789	0.541	75.676	0.9	91.361	77.835	53.831	
06-Sep 05:24	2.984	31.819	34.2	0.098	77.154	0.9	89.179	72.459	60.701	
06-Sep 05:29	2.441	32.499	33.798	0.252	77.311	1.108	96.215	72.45	55.729	
06-Sep 05:34	3.306	31.895	33.674	-0.032	74.47	1.271	88.729	72.591	61.358	
06-Sep 05:39	1.847	30.802	33.826	0.235	80.366	1.079	91.776	66.953	56.451	
06-Sep 05:44	2.767	33.739	33.393	-0.1	74.66	1.016	92.275	73.619	58.329	
06-Sep 05:49	1.287	29.9	33.807	0.347	79.645	0.93	89.261	65.995	62.916	
06-Sep 05:54	2.353	33.371	33.466	0.209	76.541	1.298	93.096	69.151	53.84	
06-Sep 05:59	2.842	31.466	33.996	0.676	75.38	1.04	90.214	67.918	58.522	
06-Sep 06:04	2.068	32.765	33.47	1.048	78.45	0.9	94.147	72.412	58.518	
06-Sep 06:09	2.551	30.466	33.861	0.15	76.806	0.975	93.911	70.833	58.828	
06-Sep 06:14	2.607	34.48	33.915	0.544	76.193	0.943	85.803	74.009	61.667	
06-Sep 06:19	2.547	32.3	33.921	0.801	76.782	0.9	95.227	76.056	60.748	
06-Sep 06:24	2.161	31.105	33.743	0.519	78.99	0.9	89.234	68.761	59.97	
06-Sep 06:29	3.129	33.107	34.0	0.481	76.304	1.156	85.0	66.292	61.379	
06-Sep 06:34	3.286	31.508	34.024	0.656	76.253	0.9	94.108	72.594	61.508	
06-Sep 06:39	2.722	31.168	34.108	1.024	77.359	0.9	90.285	69.445	58.594	
06-Sep 06:44	2.097	30.753	33.844	0.896	75.794	0.966	85.0	72.138	56.786	
06-Sep 06:49	3.581	31.825	33.751	1.061	81.973	0.964	89.002	71.217	69.177	
06-Sep 06:54	2.666	30.295	33.628	0.474	74.813	1.363	92.889	73.375	61.536	

	Treated Sweet Water			Thermo Compressor	Vaporisation Chambers				
Timestamp	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C
06-Sep 06:59	1.769	29.9	33.871	0.174	79.519	1.422	91.158	72.497	58.709
06-Sep 07:04	2.648	32.075	33.987	0.599	76.737	1.031	87.563	72.186	58.334
06-Sep 07:09	3.029	33.997	34.015	0.527	75.526	1.023	89.628	69.988	64.166
06-Sep 07:14	4.23	32.308	34.111	0.898	78.88	0.996	85.662	72.044	57.008
06-Sep 07:19	2.827	29.903	33.848	0.665	79.367	1.089	92.706	74.444	59.923

Summary

	Treated Sweet Water			Thermo Compressor	Vaporisation Chambers				
Timestamp	FT-0401 kg/hr	TT-0401 °C	TT-0402 °C	PT-E01 Bar	TT-0405 °C	PT-0401 Bar	TT-406-2 °C	TT-406-3 °C	TIC-V03 °C
Average	2.75	31.69	33.8	0.5	78.09	1.12	92.68	71.75	60.15
Max	4.59	37.23	34.2	1.1	84.23	1.7	107.78	80.5	72.1
Min	1.03	29.9	33.2	-0.1	72.53	0.9	85.0	60.49	47.0